

**Hengrove Park Forum
Response to Outstanding Queries**

Tuesday 3rd March 2009

7pm – 8.30pm

The Scout Hut, Hengrove Park, Bamfield, Bristol

Electrical Demand

A discussion took place regarding the electrical power demand of the site, the following question was raised:

Q – How many mega-watts will pass through?

• The Project team to provide a more detailed written explanation to be distributed with the meeting notes.

The answer isn't necessarily a straightforward one, since the development as a whole will have an electrical demand reached through adding together the demand for each site, this does not reflect the real-life situation, since not all the demand will be required at one time.

To allow for this Western Power are to construct a switchroom on site which will cater for the total combined demand of approximately 10MVA

Noise Levels

Another discussion focused on noise levels, and the following question was raised:

Q – Please specify increased noise and pollution levels.

A – Figures for these are available and will be posted on the Hengrove park website with the minutes.

The actual question raised referred to Noise Pollution Levels, this was covered in detail in the Environmental Statement which was prepared and submitted to support the detailed planning application.

Based on increased traffic flows, the summary statement read:

'it has been shown that the largest increase in traffic noise levels due to the Hengrove Park development is on Whitchurch Lane (West), where typical noise levels will increase by 1dB. This is below perceptible levels of change in noise and is regarded as a **Negligible Impact**.'